

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND
DYED WATER TESTING FORM

Page 3 of 3

Sewershed: Dundalk

Consultant: RJN Group, Inc.

Date: YYYYMMDD

2008 108 14

Test to be performed:

Smoke ☒ Dye ☐

Ground Condition:

Dry Damp Wet

Supervisor initials: TS

Manhole ID: S69U-012MH

Test ID: 1047- 100

Notifications - made daily: ☒
(Residents, Fire, 311)

Field Sketch: Show all manholes with numbers, blower placement location, sandbag or isolation device location, street names, building addresses and locations, defect locations and photograph numbers.

The field sketch is drawn on a grid background. It shows the intersection of two streets: Brown Ave (horizontal) and Eastbourne Ave (vertical). A third street, Kane Ave, is shown as a vertical line to the left of the intersection. Manhole S69S-025MH is located on Brown Ave, and manhole S69U-012MH is located on Eastbourne Ave. A smoke blower is positioned at the bottom of the grid, with an arrow pointing up towards the manholes. Sandbags are indicated at the top and bottom of the grid. Building addresses 6501 and 6502 are marked on the right side of the grid. The sketch also includes labels for 'Brown Ave', 'Eastbourne Ave', and 'Kane Ave'.

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND DYED WATER TESTING FORM		Page <u>3</u> of <u>3</u>
Sewershed: Dundalk	Consultant: RJN Group, Inc.	Date: YYYYMMDD <u>2008 108 114</u>
Test to be performed: Smoke <input checked="" type="checkbox"/> Dye <input type="checkbox"/>	Ground Condition: <input checked="" type="checkbox"/> Dry <input type="checkbox"/> Damp <input type="checkbox"/> Wet <input type="checkbox"/>	Supervisor initials: <u>TS</u>
Manhole ID: <u>569U-012MH</u>	Test ID: 1047- <u>100</u>	Notifications - made daily: <input checked="" type="checkbox"/> (Residents, Fire, 311)



S1047-100-OB01-P01 Private Cleanout, medium smoke, grass.



S1047-100-OB02-P01 Private Lateral, medium smoke, grass.